

Test Report

**Client:** Ezemvelo Eco Solutions Pty Ltd  
**Address:** 9 Davenport Close, MARlborough Park, Brackenfell, 7560  
**Report no:** 147142  
**Project:** Ezemvelo Eco Solutions Pty Ltd

**Date of report:** 03 March 2023  
**Date accepted:** 28 February 2023  
**Date completed:** 03 March 2023  
**Date received:** 28 February 2023

Lab no:			240026	240027	240028		
Date sampled:			27-Feb-23	27-Feb-23	27-Feb-23		
Aquatico sampled:			No	No	No		
Sample type:			Water	Water	Water		
Locality description:			Untreated Raw	Rubicon Sample 2	Rubicon Sample 1		
Analyses			Unit	Method			
A	AQL	E.coli	CFU/100ml	ALM 40	>100000	<1	<1
N	AQL	Faecal coliform	CFU/100ml	ALM 42	>100000	<1	<1
A	AQL	Total coliform	CFU/100ml	ALM 40	>100000	<1	<1

A = Accredited N = Non accredited Sub = Sub-contracted NR = Not requested RTF = Results to follow NATD = Not able to determine ATR = Alternative test report ; Results relate only to the items received and tested ; Results reported against the limit of detection; Results marked 'Non SANAS Accredited' in this report are not included in the SANAS Schedule of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory

AQL = Aquatico Laboratories ; AQK = Aquatico Laboratories based in Kathu